

TYPICAL CROSS SECTION

"A"	"Q"	
SEPARATION BETWEEN CL OF TRENCHES (mm)	DIMENSION (mm)	
750	0 600 800 1300	
1000		
1500		
2000		
2000-6000	1300	

NOTES:

- COMPACTION TESTS TO BE UNDERTAKEN BY A NATA REGISTERED TESTER FOR SEWER AND DRAINAGE TRENCH BACKFILL. RESULTS TO BE FORWARDED TO WYNDHAM CITY COUNCIL'S WORKS SUPERVISING OFFICER.
- REFER TO WYNDHAM CITY COUNCIL'S GENERAL SPECIFICATIONS, SECTION 701, FOR DETAILS ON MATERIALS AND COMPACTION CRITERIA.
- 3. DEPTH OF CLASS 3 BACKFILLING REQUIRED TO BE SHOWN ON SEWER PLAN LONGSECTIONS.
- 4. BACKFILLING REQUIREMENT APPLIES TO ALL EXISTING AND FUTURE SEWERS.

ر ا	REV	AMENDMENTS	APPROVAL	DATE	SEWER TRENCH BACKFILLING SPECIFICATION	CAD FILE: SD6-10.DWG
100	_	MINOR DRAFTING MODIFICATIONS, DELETED NOTE 5 UPDATED TO REFLECT CURRENT STANDARDS	M.BRIGANDI	16-05-07 21-05-24	FOR DRAINS IN CLOSE PROMIMITY (SEE TABLE) - EXCLUDING UNDER PAVEMENTS	DRAWN DATE: FEB 2024
Eug					A	REVISION: C
 ⊠					wyndhamcity WERRIBEE, VIC 3030 Wyndham.vic.gov.au	DRAWING NO.: SD6-10
σ					C119. CC051. CC011179	020 .0

GENERAL NOTES: -DRAWINGS ARE NOT TO SCALE.

-ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS OTHERWISE STATED. -FOR UP TO DATE DRAWINGS PLEASE CHECK WYNDHAM CITY COUNCIL WEBSITE.

-ALL STANDARD DRAWINGS TO BE USED IN CONJUNCTION WITH SD1-1 (STANDARD DRAWINGS CONDITIONS OF USE).