

EASEMENT CONNECTION TO PIPE

EASEMENT CONNECTION TO PIPE

- NOTES:**
1. ALL PIPES AND FITTINGS TO BE OF 100mm PVC CLASS SN6, REFER AS 1260.
 2. ALL PVC JOINTS TO BE SEALED WITH SOLVENT CEMENT OR RUBBER RING JOINTS.
 3. DEPTH 'D' = 400mm MINIMUM UNLESS OTHERWISE APPROVED BY COUNCIL.
 4. BED PROPERTY CONNECTION PIPE ON 50MM COMPACTED 20mm CLASS 3 CRUSHED ROCK OR CLASS 3 CRUSHED CONCRETE.
 5. BACKFILL TRENCH WITH CLASS 3 20mm CRUSHED ROCK OR CLASS 3 20mm CRUSHED CONCRETE TO 100mm ABOVE THE PROPERTY CONNECTION PIPE.
 6. TRENCH UNDER FOOTPATH TO BE BACKFILLED WITH COMPACTED 20MM CLASS 3 CRUSHED ROCK.
 7. IF THE HOLE IN THE PIT WALL FOR THE PIPE IS NOT AVAILABLE, A HOLE IS TO BE CORE DRILLED.

REINFORCED CONCRETE PIPE AS SPECIFIED

PVC PAN COLLAR WITH RUBBER RING OR APPROVED EQUIVALENT. RENDERED AROUND COLLAR WITH MORTAR

REINFORCEMENT CUT & HOLE RENDERED WITH MORTAR

100mm PVC SEWER CLASS SN6 PIPE

FOR JUNCTION PIT DETAIL REFER TO SD5-8, SD5-9 & SD5-10

1500

FINISHED SURFACE

HOUSE CONNECTION

SCREW CAP

FINISHED SURFACE

HOUSE CONNECTION

REFER TO NOTE 3


D

1 IN 30

300

CAD FILE:	SD6-3.DWG
DRAWN DATE:	FEB 2024
REVISION:	C
DRAWING NO.:	SD6-3

EASEMENT PROPERTY INLET CONNECTION



45 PRINCES HIGHWAY
WERRIBEE, VIC 3030

TEL: 1300 023 411
wyndham.vic.gov.au

GENERAL NOTES:

- DRAWINGS ARE NOT TO SCALE.
- ALL MEASUREMENTS ARE IN MILLIMETERS UNLESS OTHERWISE STATED.
- FOR UP TO DATE DRAWINGS PLEASE CHECK WYNDHAM CITY COUNCIL WEBSITE.
- ALL STANDARD DRAWINGS TO BE USED IN CONJUNCTION WITH SD1-1 (STANDARD DRAWINGS CONDITIONS OF USE).